AD-A046 666   FOREIGN TECHNOLOGY DIV WRIGHT-PATTERSON AFB OHIO   F/G 21/5
HEAT EXCHANGE IN COOLED FLOW AREA OF THE TURBINE.(U)
MAY 77   S Z KOPELEV , S V GUROV
UNCLASSIFIED   FTD-ID(RS)T-0653-77   NL

| OF |
AD
A046666

END
DATE
FILMED
12-77
DDC

FOREIGN TECHNOLOGY DIVISION

HEAT EXCHANGE IN COOLED FLOW AREA OF TURBINE

by

S. Z. Kopelev, S. V. Gurov,
M. V. Avilova-Shul'gina

D D C
NOV 21 1977
RECEIVED
D

FTD- ID(RS)T-0653-77

UNEDITED MACHINE TRANSLATION

FTD-ID(RS)T-0653-77   20 May 1977

MICROFICHE NR: *FTD-77-C-000605*

HEAT EXCHANGE IN COOLED FLOW AREA OF THE TURBINE

By: S. Z. Kopelev, S. V. Gurov, M. V. Avilova-
    Shul'gina

English pages: 25

Source: Izvestiya Akademii Nauk SSSR Energetika
        i Transport, Izd-vo "Nauka", Moscow, Nr
        4, July-August 1971, PP. 105-111

Country of origin: USSR
This document is a machine translation

FTD- ID(RS)T-0653-77   Date 20 May 19 77

U. S. BOARD ON GEOGRAPHIC NAMES TRANSLITERATION SYSTEM

Block	Italic	Transliteration	Block	Italic	Transliteration
А а	*А а*	A, a	Р р	*Р р*	R, r
Б б	*Б б*	B, b	С с	*С с*	S, s
В в	*В в*	V, v	Т т	*Т т*	T, t
Г г	*Г г*	G, g	У у	*У у*	U, u
Д д	*Д д*	D, d	Ф ф	*Ф ф*	F, f
Е е	*Е е*	Ye, ye; E, e*	Х х	*Х х*	Kh, kh
Ж ж	*Ж ж*	Zh, zh	Ц ц	*Ц ц*	Ts, ts
З з	*З з*	Z, z	Ч ч	*Ч ч*	Ch, ch
И и	*И и*	I, i	Ш ш	*Ш ш*	Sh, sh
Й й	*Й й*	Y, y	Щ щ	*Щ щ*	Shch, shch
К к	*К к*	K, k	Ъ ъ	*Ъ ъ*	"
Л л	*Л л*	L, l	Ы ы	*Ы ы*	Y, y
М м	*М м*	M, m	Ь ь	*Ь ь*	'
Н н	*Н н*	N, n	Э э	*Э э*	E, e
О о	*О о*	O, o	Ю ю	*Ю ю*	Yu, yu
П п	*П п*	P, p	Я я	*Я я*	Ya, ya

*ye initially, after vowels, and after ъ, ь; e elsewhere.
When written as ё in Russian, transliterate as yё or ё.
The use of diacritical marks is preferred, but such marks
may be omitted when expediency dictates.

GREEK ALPHABET

Name	Letters			Name	Letters		
Alpha	A	α	*α*	Nu	N	ν	
Beta	B	β		Xi	Ξ	ξ	
Gamma	Γ	γ		Omicron	O	o	
Delta	Δ	δ		Pi	Π	π	
Epsilon	E	ε	ϵ	Rho	P	ρ	ϱ
Zeta	Z	ζ		Sigma	Σ	σ	ς
Eta	H	η		Tau	T	τ	
Theta	Θ	θ	ϑ	Upsilon	Υ	υ	
Iota	I	ι		Phi	Φ	φ	φ
Kappa	K	ϰ	κ	Chi	X	χ	
Lambda	Λ	λ		Psi	Ψ	ψ	
Mu	M	μ		Omega	Ω	ω	

1

RUSSIAN AND ENGLISH TRIGONOMETRIC FUNCTIONS

Russian	English
sin	sin
cos	cos
tg	tan
ctg	cot
sec	sec
cosec	csc
sh	sinh
ch	cosh
th	tanh
cth	coth
sch	sech
csch	csch
arc sin	$\sin^{-1}$
arc cos	$\cos^{-1}$
arc tg	$\tan^{-1}$
arc ctg	$\cot^{-1}$
arc sec	$\sec^{-1}$
arc cosec	$\csc^{-1}$
arc sh	$\sinh^{-1}$
arc ch	$\cosh^{-1}$
arc th	$\tanh^{-1}$
arc cth	$\coth^{-1}$
arc sch	sech^{-1}
arc csch	csch^{-1}

rot	curl
lg	log

GRAPHICS DISCLAIMER

All figures, graphics, tables, equations, etc.
merged into this translation were extracted
from the best quality copy available.

11

HEAT EXCHANGE IN COOLED FLOW AREA OF TURBINE

S. Z. Kopelev, S. V. Gurov, M. V. Avilova-Shul'gina[2]

(Moscow)

Page 105

Are presented the results of the theoretical and experimental study of heat exchange in flow areas of the high-temperature cooled turbines GTD [ГТД - gas-turbine engine]. Are obtained criterial relationship/ratios for the generalization of the experimental data on the intensity of cooling of rotor blades under conditions of rotation.

It is shown, that the data on heat exchange, obtained at static installations, can be common for work conditions of blades under turbines. are given the experimental data on the warm-up of cooled blade of one of widespread diagrams - hollow with internal deflector illustration 5, Table 1. References 9. page 105-111.

In turbine the heat exchange on the external and internal surfaces of blades occurs in centrifugal-force field. In connection with this arises the question concerning the competence/validity of the propagation of the data, obtained at static installations, to work conditions of blades under turbines, and on the criteria, which characterize the effect of centrifugal-force field on heat exchange in turbine stage. Let us examine it in connection with the blades of two mostd widely use diagrams - with the transverse and longitudinal (relative to pen) location of cooling channels [1]. From system of equations, which describe the process of heat exchange during the nonseparable nonisothermal flow the airfoil/profile of blade of the flow about of the compressible gas, the presence of centrifugal-force field it is considered only by equation of motion

$$v\left[\frac{\partial W}{\partial \tau} + W(\text{grad } W)\right] = T - \text{grad } p + \mu \nabla^2 W. \qquad (1)$$

Here $T = \rho j$ is the mass force, referred to unit volume, j is the acceleration, which determines this force. The effect of the mass forces and forces, which create constrained motion, is characterized by difference T - grad p.

For the rotating lattice under value W let us understand the
relative speed of flow, which is equivalent to passage to the
coordinate system, connected with lattice. In this case to the
forces, which act in rigid lattice, will be addded an additional two:
centrifugal from movable centripetal acceleration J'_u and Coriolis
from Coriolis acceleration J_K.

Force T can be decomposed on three components: tangential
(circular/neighboring) T_u, radial T_r and axial T_a.

In turbine the axial accelerations in the vane channels of rotor
blades are comparatively small; therefore axial force T_a can be
excluded from examination. Bearing in mind that the tangential
component T_u is composed of the force T_t, which appears in rigid
lattice during the flow of gas in curvilinear vane channel, and
inertial Coriolis force T_K, it is possible to write

$$T = T_t \sqrt{(1 + T_K / T_t)^2 + (T_r / T_t)^2}. \qquad (2)$$

Page 106.

In turn,, the effect of force field (in our case centripetal and Coriolis) on the character of boundary-layer flow it can be revealed only when on the different sections of vane channel the amount of the mass forces is different [by 2]. After multiplying ratios T_r/Π_ϵ and T_k/Π_ϵ to simplexes $\Delta T_{r_{\text{макс}}}/T_r$ and $\Delta T_{k_{\text{макс}}}'/T_к$, we will obtain

$$\Delta T_{k_{\text{макс}}}|T_t = \text{idem}, \qquad \Delta T_{r_{\text{макс}}}|T_t = \text{idem}. \tag{3}$$

In the vane channel of the cooled revolving gate in radial direction in particle act the mass centrifugal forces $T_ц$ translational acceleration and the lifts $T_п$, caused by heterogeneous density.

Consequently, for the similarity of the processes of heat exchange it is necessary

$$(\Delta T_{r_{\text{макс}}}|T_t)_ц = \text{idem}, \ (\Delta T_{r_{\text{макс}}}|T_t)_п = \text{idem}, \ \Delta T_{r_{\text{макс}}}|T_t = \text{idem}. \tag{4}$$

The maximum centrifugal acceleration in revolving gate occurs on periphery, minimum - in root section. The maximum difference in the centrifugal forces can be written (see Fig. 1):

$$(\Delta T_{r_{\text{макс}}})_{\text{ц}} = \gamma h F_{\text{м.к}} \left(\frac{u_{\text{п}}^2}{r_{\text{п}}} - \frac{u_{\text{к}}^2}{r_{\text{к}}} \right). \qquad (6)$$

After designating $2r_{\text{ср}}/h = \chi$, we will obtain

$$(\Delta T_{r_{\text{макс}}})_{\text{ц}} = \gamma F_{\text{м.к}} u_{\text{ср}}^2 / \chi^2. \qquad (6)$$

the force of periphery, which acts on blade,

$$T_t = \frac{G_t}{Z}(W_{1u} - W_{2u}), \qquad (7)$$

here G_t - the gas flow through lattice, z - the number of blades.

From the equation of the continuity

$$G_{\mathrm{r}} = \gamma W_a t h z. \qquad (8)$$

By taking into account (6) - (8), it is possible to write

$$\left(\frac{\Delta T_{r_{\text{макс}}}}{T_t} \right)_{\text{ц}} = \frac{u_{\text{ср}}^2}{\chi^2} \frac{F_{\text{м.к}}}{(W_{1u} - W_{2u}) W_a t h}$$
$$(9)$$

Since the cross-sectional area of vane channel (without taking into account of real profile thickness)$F'_{\text{м.к}} = \pi d_{\text{ср}} b / z$, after conversions we will obtain

$$K_{\text{ц}} = \left(\frac{\Delta T_{r_{\text{макс}}}}{T_t} \right)_{\text{ц}} = \frac{1}{\mu} \frac{u_{\text{ср}}}{W_a} \frac{b}{h} \frac{1}{\chi^2}. \qquad (10)$$

Here $\mu = L_u / u_{cp}^2$ is a factor of the load (L_u — the work, given up by the blade rim of elementary step/stage, referred to 1 kg of working medium/propellant).

The kinematics of the step/stage of turbine usually is characterized four by parameters - by dimensionless work (coefficient μ), by the dimensionless axial velocity W_a / u_{cp}, by the degree of reaction μ and by the relation of axial velocities W_{1a} / W_{2a}. However, with acceptable for a practice accuracy by its it is possible to assign only two parameters - μ and W_a / u_{cp}. Consequently, the first two factors in formula (10) reflect the kinematic similarity of step/stages. The latter fact was not considered by some researchers [3, 4].

Fig. 1.

Fig. 1. Schematic of the elementary step/stage of turbine.

Page 107.

Relative speed W_a/u_{cp} is connected with flow angles at entrance and exit from lattice by the relationship/ratio

$$\frac{W_a}{u_{cp}} = \frac{\mu}{\operatorname{ctg} \beta_1 + \operatorname{ctg} \beta_2}. \qquad (11)$$

Then

$$K_a = \frac{1}{\mu^2} \frac{\operatorname{ctg} \beta_1 + \operatorname{ctg} \beta_2}{\chi^2 \bar{h}}. \qquad (12)$$

Here $\bar{h} = h/b$ is strain of blade. Hence it follows that for the concrete/specific/actual step/stage

$$K_a = f(\mu). \qquad (13)$$

the maximum amount of Coriolis forces occurs of the root of

blade and on periphery, since they on module/modulus are equal to $2\gamma\omega W_r$

(here ω - the angular rate of rotation of lattice, W_r - the speed of

the secondary flows). The relationship/ratio of the velocity of the

secondary flows and mean-expenditure over section velocity is changed

insignificantly [5]. After accepting it as constant, we will obtain

that in the lattices impellers the effect of Coriolis forces on heat

exchange with an accuracy to constant is characterized by that

expression for a criterion $K_{\text{ц}}$, that also the effect of centrifugal

forces.

In the intensely cooled lattices impellers the maximum

nonisothermicity in flow $\Delta T_r = T_r - T_{cr}$, here T_r, T_{cr} - are temperatures of

flow and wall of blade. Therefore

$$Gr_r = 2\frac{\Delta T_r}{T_r}\frac{1}{\mu^2\chi h} \qquad (14)$$

or, for a concrete/specific/actual step/stage,

$$\overset{\text{II.}}{Gr_r} = f(\Delta T_r / T_r \mu^2).\qquad\qquad(15)$$

If we consider the radial cooling channel in blade as pipe of constant cross-section, then equation of motion can be written in the form

$$dp + \gamma W dW = -\zeta \frac{\gamma W^2}{2} \frac{dh}{D} + \gamma \frac{u^2}{r} dh,\qquad\qquad(16)$$

where ζ is a coefficient of friction, D - the hydraulic diameter of

channel, and the action of centrifugal forces is considered by positive term $\gamma u^2 dh/r$.

After accepting as characteristic linear size the height/altitude of channel h and after dividing both parts of the equation of motion to velocity head at output/yield from channels γW_s^2, we will obtain

$$K_u^{\bullet} = \frac{u_{cp}^2}{W_s^2 \chi^2}.$$ (17)

According to the equation of the continuity

$$W_s = G_s / \gamma F_s.$$ (18)

Since $G_s = G_r \bar{G}_s$, keeping in mind (8), it is possible to write

$$K_u^{\bullet} = K_u^r \frac{h}{\bar{C}_s^2 (F_r/F_s z)}.$$ (19)

In blades with the transverse (relative to pen) location of cooling channels their value δ, as a rule, is constant or is changed insignificantly; therefore

$$T_t^\bullet = (\bar{G}_s G_r / z)(W_{1u}^\bullet - W_{2u}^\bullet) = \bar{G}_s \gamma_u (W_{1u}^\bullet - W_{2u}^\bullet) W_a th. \qquad (20)$$

Bearing in mind that

$$W_{1u}^\bullet = W_{1u}\frac{W_a^\bullet}{W_a}, \quad W_{2u}^\bullet = W_{2u}\frac{W_a^\bullet}{W_a}, \quad \frac{W_a^\bullet}{W_a} = \bar{G}_s\frac{t}{\delta},$$

we will obtain

$$T_t^\bullet = \bar{G}_s(t/\delta)\gamma(W_{1u} - W_{2u})W_a th. \qquad (21)$$

Page 108.

Maximum difference in the centrifugal forces

$$(\Delta T_{r_{\text{макс}}})_{u} = \gamma F_{\text{м.к}} u_{\text{ср}}{}^{2}/\chi^{2} \qquad (22$$

and

$$F_{\text{м.к}} = \pi d_{\text{ср}} b \delta / tz. \qquad (23)$$

By utilizing expressions (20) - (23), it is possible to write

$$\left(\frac{\Delta T_{r_{\text{макс}}}}{T_{t}}\right)_{\text{ц}} = \frac{1}{\mu \bar{G}_{\text{в}}} \frac{u}{W_{a}} \frac{(\delta t)^{2}}{\chi^{2}\bar{h}},$$

or

$$K_{\text{ц}}{}^{\ast} = K_{\text{ц}}{}'(\delta/t)^{2}/\bar{G}_{\text{в}}^{2}. \qquad (24)$$

Thus, for each concrete/specific/actual step/stage the effect of centrifugal forces on heat exchange is characterized by three parameters: 1) by the factor of the load of step/stage μ, 2) by

relation $\Delta T_r / T_r$ and 3) by the relative air flow rate for cooling $\overline{G}_B$.

Experimental research of blades with the transverse location of cooling channels was conducted on static packages and on three turbine stages. Their size/dimensions differed among themselves more than 2.5 times. The construction of stand of static packages, the procedure of experiments and processing the experimental data are given in [6]. The fundamental geometric characteristics of the tested lattices are given in table.

The design concept of rotors is given in [7]. Before tests were obtained the discharge characteristics of channels in trailing edges, deflectors and blades in collection with deflectors. The stability of characteristics was checked both in the process of tests and after their completion.

The thermal condition of blades was estimated at the dimensionless coefficient $\theta = (t_r - t_a) / (t_r - t_s)$, which are the virtually single-valued function of the ratio of heat-transfer coefficients from air and gas. The temperature of the stagnant (in relative motion) flow of gas on blades t_r was determined from measurement by the special thermocouples, established/installed on blades, and but to the measurements of the temperature field of gas after turbine. Both methods ensured completely satisfactory agreement. The

temperature of blades was measured by the thermccouples, established/installed into four points on airfoil/profile (entering edge, back, the concave part of the airfoil/prcfile, trailing edge) and in three sections by height (root, average, peripheral). Each measurement conducted simultaneously on three blades. The transmission of thermocurrents to recorder (electronic potentiometer EPP-09) was realized through the mercury slip ring. The temperature of air coolant $T_в'$, pressure $p_в'$ and its expenditure/consumption were measured directly at the entrance into rotor [7].

(1) Геометрические параметры	(2) Номера решеток			
	1	2	3	4
(3) Хорда l, мм	78	49	60	41
(4) Шаг t, мм	47	31	43	32
(5) Ширина b, мм	74	45	57	41
(6) Угол входа $\beta_{1к}$	53°	55°	56°	38°
(7) Угол выхода $\beta_{2к}$	37°	31°30'	42°	32°30'
(8) Диаметр входной кромки D, мм	4,8	4,0	4,7	5,8
(9) Диаметр выходной кромки d, мм	2,8	2,4	2,7	1,7
(10) Относительная высота %	5,0	9,0	5,5	5,3
	(11) Лопатки с переменным по высоте профилем		(12) Лопатки постоянного профиля	

Key: (1). Geometric parameters. (2). Numbers of lattices. (3). Chord

l mm. (4). Space t, mm. (5). Width b, mm. (6). Angle of entry

(7). Angle of departure   (8). Diameter of entering edge D, mm.

(9). Diameter of trailing edge d, mm. (10). Relative height/altitude

(11). Blades with alternating/variable by height airfoil/profile.

(12). Blades of constant airfoil/profile.

Page 109.

Since during air flow from the place of measurement to the

section of blade in question its temperature increases because of the

work of centrifugal forces, the temperature t_β during the definition

of coefficient θ was computed as sum $t_n^* = t_3' + (u^2/2c_p J)$, here u is the

peripheral speed in the section in question, c_p – is heat capacity of

the air, J - termal equivalent of work.

The estimation of leakages according to labyrinth seals,

clearances in the circuit of supply and the scarf joint of blades

with disk conducted according to datum, on obtained by the

preliminary blasting of rotors [7]. The broad band of a change in the

parameters μ, $\Delta T_r/T_r$ and $\bar{G}_n$ was achieved by a change in the load of

turbine, number of revolutions (55-100c/o), of the temperature of the

gas before turbine (650-1490°K), the temperatures of air coolant

(350-800°K), and the expenditure/consumption of the air,

take/selected for cooling (0.8-3.3o/o).

Fig. 2.

Fig. 2. Effect of centrifugal-force field on heat exchange in the cooling channels: 1.2.3 - lattice 1.2.3 in statics, 4.5.6 - in rotation.


Fig. 3. The effect of the loading of turbine on heat emission in vane channels for a trailing edge (see designations to Fig. 2), $\bar{\theta}$ is a ratio of the intensities of cooling in rotation and in statics.

Fig. 4. The effect of cooling lattice on heat emission in vane channels for a trailing edge (see designations to Fig 2).

Page 110.

During processing the experimental data the mode/conditions of tests were grouped in such a way as to determine the effect of each of these parameters individually.

On Fig. 2 are shown the results in order to determine the effect

of each of these parameters individually.

On Fig. 2 are shown the results of the generalization of the experimental data, $\mu = 1.6$ = const, $\Delta T_r / T_r = 0.26$ = const. Generalization is made for the section of trailing edge, analogous dependences are obtained also for an entering edge and concave - convex parts of the airfoil/profile.

On Fig. 3 is shown the effect of the loading of the step/stage of turbine on heat emission from gas to blade on section III ($\Delta T_r / T_r = 0.15$ = const, $\bar{G}_\text{в} = 1.8$о/о = of const), while on Fig 4 - density in nonisothermal flow ($\mu = 1.75; \bar{G}_\beta = 3.3$о/о). As is evident, in the range of a change of the parameters μ, $\Delta T_r / T_r$ and $\bar{G}_\text{в}$ in question the rate of heat exchange under the static conditions and during rotation (with different number of revolutions) remains virtually constant/invariable. Analogous results are obtained for the sections of blade I, II.

The experimental study of the thermal condition of blades with the longitudinal (relative to pen) location of cooling channels is undertaken in [8] (see table, lattice 4).

The temperature of gas on blades during tests was maintained by constant/invariable and equal to 1440°K, air -310°K,

expenditure/consumption -1.8o/o. From Fig. 5 it is evident that the coefficient θ also virtually is not changed in all investigated velocity range (6500-12500 r/min: μ = 1.0-1.5. Even a very substantial change in the angle of the inleakage (from -20 to +7°) of the flow of gas to rotor blades (Fig. 5) does not affect their temperature.

It is necessary to keep in mind that the level of flow turbulence in the static installations, where the preheating of air is realized in combustion chambers GTD, is so great that upon transition to revolving gates the effect on it of the velocity of the rotation impeller is not exhibited [9].

Conclusions. 1. In the investigated range of a change of the parameters μ, $\Delta T_r / T_r$ and $\bar{C}_\theta$ characteristic for turbines of GTD, the intensity of heat exchange in air-cooled blades, measured during tests at static installations and in turbine stages under conditions of rotation, remains constant/invariable.

2. The experimental data, obtained at static installations, can be common for work conditions of blades under turbines, which substantially simplifies the procedure of experiment and the construction of test benches.

Fig 5

Fig. 5. Effect of the loading of turbine on the dimensionless
temperature of blade with the longitudinal (relative to pen) location
of cooling channels.

Page 111.

Bibliography.

1. S. K. Tumanskiy. TRD [$TP\underline{A}$ } - turbojet engine] for high
speeds. Aviation and astronautics, 1966, No 2.

2. V. K. Shchukin. Additional condition of the similarity of
flows under the fields of the mass inertial forces. Works Kazan
aviation institute, 1963, iss. 76.

3. V. A. Trushin, V. I. Lokay. Rotational effect on heat
exchange between gas and cell/elements of flow area of the gas
turbine. Izv. of VUZ [$B\mathcal{Y}\mathcal{J}$ - Institute of Higher Education].
Aviation equipment, 1968, No 3.

4. V. L. Ivanov, E. A. Manushin, Yu. D. Lapin. Some results of
the experimental study of the cooled turbine. Izv. of VUZ. Aviation
equipment, 1966, No 2.

5. D. Prandtl. Seaplane mechanic. IL, 1950.

6. S. V. Gurov. Study of the intensity of cooling deflector blade. Thermal-power engineering, 1967, No 10.

7. S. Z. Kopelev, S. V. Gurov. Hydraulic resistance of the system of air cooling. Into book "heat exchange in power plants". "Naukova dumka", 1967.

8. N E Waldren, J A Flint, P E Barnes. Mechanical Aspects of Turbine Blade Cooling. ARC RM, 1965, N 3404.

9. V. d. Kurosh, E. Ya. of epics. On the eddying effect of flow to heat exchange in flow area of the turbomachines. Coll. "heat exchange". "Naukova dumka", 1970.

Submitted 12 June 1970.

REPORT DOCUMENTATION PAGE		READ INSTRUCTIONS BEFORE COMPLETING FORM
1. REPORT NUMBER FTD-ID(RS)T-0653-77	2. GOVT ACCESSION NO.	3. RECIPIENT'S CATALOG NUMBER
4. TITLE *(and Subtitle)* HEAT EXCHANGE IN COOLED FLOW AREA OF TURBINE		5. TYPE OF REPORT & PERIOD COVERED Translation
		6. PERFORMING ORG. REPORT NUMBER
7. AUTHOR(s) S. Z. Kopelev, S. V. Gurov, M. V. Avilova Shul'gina		8. CONTRACT OR GRANT NUMBER(s)
9. PERFORMING ORGANIZATION NAME AND ADDRESS Foreign Technology Division Air Force Systems Command U. S. Air Force		10. PROGRAM ELEMENT PROJECT, TASK AREA & WORK UNIT NUMBERS
11. CONTROLLING OFFICE NAME AND ADDRESS		12. REPORT DATE July-August 1971
		13. NUMBER OF PAGES 25
14. MONITORING AGENCY NAME & ADDRESS(if different from Controlling Office)		15. SECURITY CLASS. (of this report) UNCLASSIFIED
		15a. DECLASSIFICATION DOWNGRADING SCHEDULE

16. DISTRIBUTION STATEMENT *(of this Report)*

Approved for public release; distribution unlimited

17. DISTRIBUTION STATEMENT *(of the abstract entered in Block 20, if different from Report)*

18. SUPPLEMENTARY NOTES

19. KEY WORDS *(Continue on reverse side if necessary and identify by block number)*

20. ABSTRACT *(Continue on reverse side if necessary and identify by block number)*

13;20;21

DD FORM
1 JAN 73 **1473** EDITION OF 1 NOV 65 IS OBSOLETE

DISTRIBUTION LIST

DISTRIBUTION DIRECT TO RECIPIENT

ORGANIZATION		MICROFICHE	ORGANIZATION		MICROFICHE
A205	DMATC	1	E053	AF/INAKA	1
A210	DMAAC	2	E017	AF/RDXTR-W	1
B344	DIA/RDS-3C	8	E404	AEDC	1
C043	USAMIIA	1	E408	AFWL	1
C509	BALLISTIC RES LABS	1	E410	ADTC	1
C510	AIR MOBILITY R&D LAB/FIO	1	E413	ESD	2
C513	PICATINNY ARSENAL	1		FTD	
C535	AVIATION SYS COMD	1		CCN	1
C557	USAIIC	1		ETID	3
C591	FSTC	5		NIA/PHS	1
C619	MIA REDSTONE	1		NICD	5
D008	NISC	1			
H300	USAICE (USAREUR)	1			
P005	ERDA	1			
P055	CIA/CRS/ADD/SD	1			
NAVORDSTA (50L)		1			
NAVWPNSCEN (Code 121)		1			
NASA/KSI		1			
AFIT/LD		1			